



Ref. Certif. No.

CN39901-A1/M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product

Moulded Case Circuit-breakers

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

NOARK Electrics (Shanghai) Co., Ltd.  
No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China

*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

See the Appendix

Trademark (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

NM8N-1600, NM8NDC-1600

Additional information (if necessary may also be reported on page 2)

IEC 60947-2:2016(5th Edition)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2019CQC-085133-M1

This CB Test Certificate is issued by the National Certification Body

**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China  
Tel: +86-10-83886666 Fax: +86-10-83886282  
website: <http://www.cqc.com.cn>



陆梅

Signature:

Lu Mei

**CB 0053919**

NM8N-1600,NM8NDC-1600

Uimp:8kV

Ui:1000V

Ue: AC380/400/415V, AC440V(Only Thermo-magnetic),

AC500V(Only Thermo-magnetic), AC660/690V, DC1000V(Only NM8NDC-1600,4P),

DC750V(Only NM8NDC-1600,3P)

In:630A, 800A, 1000A, 1250A, 1600A(Maximum In for motor protective circuit-breaker:1250A)

Type of Over-current Release: Thermo-magnetic, Electronic

Thermo-magnetic:

Ics:

AC380/400/415V:50kA/70kA/70kA(S/Q/H);

AC440V: 40kA/50kA(S/Q);

AC500V: 30kA/40kA(S/Q);

AC660/690V: 30kA;

DC1000V: 25kA/36kA(B/C);

DC750V: 25kA/36kA(B/C);

Icu:

AC380/400/415V: 50kA/70kA/100kA(S/Q/H);

AC440V: 50kA/65kA(S/Q);

AC500V: 40kA/50kA(S/Q);

AC660/690V: 30kA;

DC1000V: 25kA/36kA(B/C);

DC750V: 25kA/36kA(B/C);

Electronic:

Ics:AC380/400/415V: 50kA/70kA/70kA(S/Q/H);AC660/690V: 30kA;

Icu:AC380/400/415V: 50kA/70kA/100kA(S/Q/H);AC660/690V: 30kA;


Icw:20kA/1s(Electronic)

Page 1 of 2

Additional information (if necessary)

Date: Sep.16,2019

Signature:



Lu Mei


Selectivity category:A(Thermo-magnetic), B(Electronic)  
Poles:3P, 4P(3 protected poles with a switched neutral pole)  
Suitability for isolation  
50/60Hz  
Accessories with electronic circuits:  
Shunt release: AC220/230V, AC380/400V  
Undervoltage release:AC220/230V, AC380/400V  
Auxiliary contacts and Alarm contacts: AX21-M8,AL21-M8  
3NO3NC  
Ith:5A ;  
AC-15:Ue/Ie:AC110V/5A,AC240V/4A,AC415V/2A;  
DC-13:Ue/Ie:DC110V/0.25A,DC220V/0.25A

Page 2 of 2

Additional information (if necessary)

Date: Sep.16,2019

Signature:



Lu Mei