



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE190304006467

Product Switch disconnecter

Applicant Zhejiang CHINT Electrics Co., Ltd.

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Type/Model NM8NSD-1600;

Technical data See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No.
00901-CE2019CQC0304-010514, the submitted sample(s) of the above item complies
with:

EN 60947-3:2009 + A1:2012 + A2:2015

and fulfills testing requirements of the European Directive:

2014/35/EU

Valid from: Sep.16,2019

Valid until: Jul.12,2022

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE190304006467

NM8NSD-1600

Uimp: 12kV;

Ui: 1000V(AC),1500V(DC);

Ith=1600A (Ie: 630A, 800A, 1000A, 1250A, 1600A);

Ue: AC380V/415V/440V, AC500V, AC660/690V, DC750V(3P appearance), DC1000V(4P appearance), DC1200V(4P appearance), DC1500V(4P appearance);

Ie: 630A, 800A, 1000A, 1250A, 1600A;

Icw: 20kA(AC)/1s/3s, 19.2kA(DC)/1s;

Icm(peak): 40kA(AC); Icm:19.2kA(DC);

AC-22A, AC-23A, DC-22A, DC-22B;

3P, 4P;

50/60Hz;

Auxiliary contact (CE190302006249): 3NO3NC;

Ith: 2.5A;



AC-15: Ue/Ie: AC110V/5A, AC240V/4A, AC415V/2A;

DC-13: Ue/Ie: DC110V/0.25A, DC220V/0.25A;

Connection diagram for DC:

3P appearance (DC 750V)

4P appearance (DC1000V,DC1200V,DC1500V)



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>